



Elektrotehnički institut Nikola Tesla, Beograd
Electrical Engineering Institute Nikola Tesla, Belgrade
Centar za elektroenergetske objekte
Electrical Power Facilities Department

ISO 27001

BUREAU VERITAS
Certification



ISO 9001
ISO 14001
ISO 45001

BUREAU VERITAS
Certification



Zaključak/Conclusion

Br./N° 325665

Korisnik: Client:	Blister Properties d.o.o. ul. Generala Vasića br. 1, Beograd, Savski venac
Vrsta ispitivanja: Type of testing:	Ispitivanje izloženosti ljudi elektromagnetskom polju niskih učestanosti. Testing of human exposure to low-frequency electromagnetic fields.
Ispitivani objekat: Testing object:	Lokacija budućeg stambeno-poslovnog kompleksa „Nebessa kvart“ na Bežanijskoj kosi, na KP 7074 (nastalaj od 799/3, KP 799/17, KP 800/16 i KP 800/17) KO Novi Beograd. Location of the future residential–commercial complex „Nebessa kvart“ on Bežanijska Kosa, on cadastral parcel 7074 (formed of 799/3, 799/17, 800/16 and 800/17), Cadastral Municipality Novi Beograd.
Cilj ispitivanja: Purpose of the testing:	Provera usaglašenosti sa normativnim dokumentima. Verification of compliance with normative documents.
Normativna dokumenta:	<ul style="list-style-type: none">- Zakon o zaštiti od nejonizujućih zračenja, Službeni glasnik RS br. 36/09 od 15. 05. 2009.- Pravilnik o granicama izlaganja nejonizujućim zračenjima, Službeni glasnik RS br. 16 od 26. 02. 2025.- Pravilnik o izvorima nejonizujućih zračenja od posebnog interesa, vrstama izvora, načinu i periodu njihovog ispitivanja, Službeni glasnik RS br. 16 od 26. 02. 2025.
Normative documents:	<ul style="list-style-type: none">- <i>Law on Protection from Non-Ionizing Radiation, Official Gazette of the Republic of Serbia No. 36/09 of May 15, 2009.</i>- <i>Rulebook on Exposure Limits to Non-Ionizing Radiation, Official Gazette of the Republic of Serbia No. 16 of February 26, 2025.</i>- <i>Rulebook on Sources of Non-Ionizing Radiation of Special Interest, Types of Sources, and the Manner and Period of Their Testing, Official Gazette of the Republic of Serbia No. 16 of February 26, 2025.</i>
Rezultati ispitivanja:	Na osnovu rezultata ispitivanja, zaključuje se da je izloženost ljudi elektromagnetskom polju niskih učestanosti na lokaciji predviđenoj za izgradnju stambeno-poslovnog kompleksa na Bežanijskoj kosi, na katastarskim parcelama KP 799/3, KP 799/17, KP 800/16 i KP 800/17 KO Novi Beograd, GO Novi Beograd, Beograd, u skladu sa navedenim normativnim dokumentima, odnosno da je lokacija izvan zone uticaja TS „Beograd 5”.
Testing result:	<i>Based on the test results, it is concluded that human exposure to low-frequency electromagnetic fields at the location intended for the construction of the residential–commercial complex on Bežanijska Kosa, on cadastral parcels KP 799/3, KP 799/17, KP 800/16 and KP 800/17, Cadastral Municipality Novi Beograd, Municipality of Novi Beograd, Belgrade, is in accordance with the referenced normative documents, i.e. that the location is outside the impact zone of the Substation "Beograd 5".</i>

Napomena: Zaključak se izdaje na osnovu izveštaja br. 325614-L

Note: The conclusion is issued on the basis of Report N° 325614-L

Beograd
Belgrade

15.10.2025.

M.P.



Direktor Centra za EEO
Department Manager

Aleksandar Pavlović, dipl. inž..
Aleksandar Pavlovic, BSc. EE.